

FOR YOUR INFORMATION

(DISTANCES)

↙ SEPTIC FIELD DISTANCE TO ↘

HOUSE	16 ft. (5m)
DUG WELL	100 ft. (30m)
DRILLED WELL	50 ft. (15m)
PROPERTY LINE	10 ft. (3m)
LAKE, RIVER, ETC.	50 ft. (15m)

↙ SEPTIC TANK DISTANCE TO ↘

HOUSE	5 ft. (1.5m)
DUG WELL	50 ft. (15m)
DRILLED WELL	50 ft. (15m)
PROPERTY LINE	10 ft. (3m)
LAKE, RIVER, ETC.	50 ft. (15m)

LEACHING PITS:

33 ft. (10m) from any drilled well with a water tight casing to a depth of 20 ft (6m)
50 ft. (15m) from any dug well, sand point, spring or any source of potable water
50 ft. (15m) from any lake, pond, river, stream, reservoir or any water course
10 ft. (3m) from any property line

The septic tank should be pumped after the first year of use to determine the frequency of pumping.

Keep a maintenance record of your septic system.

*Common household habits that are problem creators:
Grease, coffee grounds, bones cooking fats, cigarette butts, disposable
diapers, paper towels, tissue, condoms, feminine products, etc.*